

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2155145-2  
**Report Reference** EX5302-20061116  
**Date** 17-May-2023

**Issued to:** RELIABLE AUTOMATIC SPRINKLER CO INC  
1470 Smith Grove Rd Liberty, SC 29657  
United States

**This is to certify that  
representative samples of**

VKYL - Special System Water Control Valves, Assembled  
Units

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** UL 260, 7th Ed., Issue Date: 2004-3-17, Revision Date:  
2018-7-3

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

  
Deborah Jennings-Conner, VP Regulatory Services  
UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2155145-2  
**Report Reference** EX5302-20061116  
**Date** 17-May-2023

**Issued to:** RELIABLE AUTOMATIC SPRINKLER CO INC  
1470 Smith Grove Rd Liberty, SC 29657  
United States

**This is to certify that representative samples of** VKYL - Special System Water Control Valves, Assembled Units

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 260, 7th Ed., Issue Date: 2004-3-17, Revision Date: 2018-7-3

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services

UL LLC




Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2155145-2  
**Report Reference** EX5302-20061116  
**Date** 17-May-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

| Model  | Category Description |
|--|----------------------|
| DDX PrePak, 2, 2.5, 3, 4, 6 and 8 in. sizes, consisting of a Listed Model DDX deluge riser assembly with Wet Pilot, Dry Pilot, Electric Actuation, Single Interlock Dry Pilot, Single Interlock Wet Pilot, Single Interlock Electric and Non-Interlock/Electric Listed Gast Model 5HCD-108-M550NGX 3/4 hp (1-1/2 hp Gast Model 7HDD-16-M750X optional for 6 in. size only) tank-mounted air compressor, an 8-gallon ASME rated air tank, Listed Model A-2 pressure maintenance device, Listed Potter Model PFC-4410-RC releasing/control panel and an electrically operated solenoid valve. This unit is intended to provide a pre-action, single or double interlock function by electrical operation, pneumatic or manual operation via a Listed Model B manual emergency station. | Assembled Unit       |
| DDX PrePak with Type D Double Interlock trim, 2, 2.5, 3, 4, 6 and 8 in. sizes, consisting of a Listed Model DDX deluge riser assembly, Listed Gast Model 5HCD-108-M550NGX 3/4 hp (1-1/2 hp Gast Model 7HDD-16-M750X optional for 6 in. size only) tank-mounted air compressor, an 8-gallon ASME rated air tank, Listed Model A-2 pressure maintenance device, Listed Potter Model PFC-4410-RC releasing/control panel and an electrically operated solenoid valve. This unit is intended to provide a pre-action, single or double interlock function by electrical operation or manual operation via a Listed Model B manual emergency station.   | Assembled Unit       |
| DDX PrePak with Type F Double Interlock trim, 2, 2.5, 3, 4, 6 and 8 in. sizes, consisting of a Listed Model DDX deluge riser assembly, Listed Gast Model 5HCD-108-M550NGX 3/4 hp (1-1/2 hp Gast Model 7HDD-16-M750X optional for 6 in. size only) tank-mounted air compressor, an 8-gallon ASME rated air tank, Listed Model A-2 pressure maintenance device, Listed Potter Model PFC-4410-RC releasing/control panel and an electrically operated solenoid valve. This unit is intended to provide a pre-action, single or double interlock function by electrical operation, pneumatic or manual operation via a Listed Model B manual emergency station.  | Assembled Unit       |

  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>





# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2155145-2  
**Report Reference** EX5302-20061116  
**Date** 17-May-2023

DDX PrePak with Type LP-Dry Single Interlock trim, 2, 2.5, 3, 4, 6 and 8 in. sizes, consisting of a Listed Model DDX deluge riser assembly, Listed Gast Model 5HCD-108-M550NGX 3/4 hp (1-1/2 hp Gast Model 7HDD-16-M750X optional for 6 in. size only) tank-mounted air compressor, an 8-gallon ASME rated air tank, Listed Model A-2 pressure maintenance device. This unit is intended to provide a single interlock function by pneumatic or manual operation via a Listed Model B manual emergency station.

Assembled Unit

*Deborah Jennings-Conner*  
Deborah Jennings-Conner, VP Regulatory Services  
UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2146413-2  
**Report Reference** EX5302-20061116  
**Date** 17-May-2023

**Issued to:** RELIABLE AUTOMATIC SPRINKLER CO INC  
1470 Smith Grove Rd Liberty, SC 29657  
United States

**This is to certify that representative samples of** VKYL7 - Special System Water Control Valves, Assembled Units Certified for Canada  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** ULC/ORD C260, 1st Ed., Issue Date: 1975-02-28

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

  
Deborah Jennings-Conner, VP Regulatory Services  
UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2146413-2  
**Report Reference** EX5302-20061116  
**Date** 17-May-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

| Model  | Category Description |
|--|----------------------|
| DDX PrePak, 2, 2.5, 3, 4, 6 and 8 in. sizes, consisting of a Listed Model DDX deluge riser assembly with Wet Pilot, Dry Pilot, Electric Actuation, Single Interlock Dry Pilot, Single Interlock Wet Pilot, Single Interlock Electric and Non-Interlock/Electric Listed Gast Model 5HCD-108-M550NGX 3/4 hp (1-1/2 hp Gast Model 7HDD-16-M750X optional for 6 in. size only) tank-mounted air compressor, an 8-gallon ASME rated air tank, Listed Model A-2 pressure maintenance device, Listed Potter Model PFC-4410-RC releasing/control panel and an electrically operated solenoid valve. This unit is intended to provide a pre-action, single or double interlock function by electrical operation, pneumatic or manual operation via a Listed Model B manual emergency station. | Assembled Unit       |
| DDX PrePak with Type D Double Interlock trim, 2, 2.5, 3, 4, 6 and 8 in. sizes, consisting of a Listed Model DDX deluge riser assembly, Listed Gast Model 5HCD-108-M550NGX 3/4 hp (1-1/2 hp Gast Model 7HDD-16-M750X optional for 6 in. size only) tank-mounted air compressor, an 8-gallon ASME rated air tank, Listed Model A-2 pressure maintenance device, Listed Potter Model PFC-4410-RC releasing/control panel and an electrically operated solenoid valve. This unit is intended to provide a pre-action, single or double interlock function by electrical operation or manual operation via a Listed Model B manual emergency station.   | Assembled Unit       |
| DDX PrePak with Type F Double Interlock trim, 2, 2.5, 3, 4, 6 and 8 in. sizes, consisting of a Listed Model DDX deluge riser assembly, Listed Gast Model 5HCD-108-M550NGX 3/4 hp (1-1/2 hp Gast Model 7HDD-16-M750X optional for 6 in. size only) tank-mounted air compressor, an 8-gallon ASME rated air tank, Listed Model A-2 pressure maintenance device, Listed Potter Model PFC-4410-RC releasing/control panel and an electrically operated solenoid valve. This unit is intended to provide a pre-action, single or double interlock function by electrical operation, pneumatic or manual operation via a Listed Model B manual emergency station.  | Assembled Unit       |

*Deborah Jennings-Conner*  
Deborah Jennings-Conner, VP Regulatory Services  
UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2146413-2  
**Report Reference** EX5302-20061116  
**Date** 17-May-2023

DDX PrePak with Type LP-Dry Single Interlock trim, 2, 2.5, 3, 4, 6 and 8 in. sizes, consisting of a Listed Model DDX deluge riser assembly, Listed Gast Model 5HCD-108-M550NGX 3/4 hp (1-1/2 hp Gast Model 7HDD-16-M750X optional for 6 in. size only) tank-mounted air compressor, an 8-gallon ASME rated air tank, Listed Model A-2 pressure maintenance device. This unit is intended to provide a single interlock function by pneumatic or manual operation via a Listed Model B manual emergency station.

Assembled Unit

*Deborah Jennings-Conner*  
Deborah Jennings-Conner, VP Regulatory Services  
UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>