

## Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
R3216	11.2	Pendent	QR	Fusible	3/4	Brass	165, 212 (74, 100)
R3216	11.2	In-Rack Pendent	QR	Fusible	3/4	Brass	165, 212 (74, 100)

Prepared for:

The Reliable Automatic Sprinkler Co., Inc.  
1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc.  
1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2005, 2009

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3050175

Approval Granted: April 21, 2014


To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

Richard B. Dunne  
Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



Member of the FM Global Group



# APPROVED

## Certificate of Compliance

This certificate is issued for the following equipment:

Product	Type	Sprinklers FM Approved with	Sprinkler Types
D-8	Guard	R3216	Pendent Automatic Sprinklers
D-9	Guard/Shield	R3216	Pendent Automatic Sprinklers

Prepared for:

The Reliable Automatic Sprinkler Co., Inc.  
1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc.  
1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2091  
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3050175

Approval Granted: April 21, 2014

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

Richard B. Dunne  
Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



Member of the FM Global Group