

# APPROVED

## Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
R3226	11.2	Upright	QR	Fusible	3/4	Brass	165, 212 (74, 100)

Prepared for: Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC, 29657

Manufacturing Location: Reliable Automatic Sprinkler Co., Inc., 1470 Smith Grove Road, Liberty, SC, 29657

FM Approvals Class: 2009

FM Approval Standard: Class Series 2000 (March 2006)


Approval Identification: 3042082

Approval Granted: November 22, 2011

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

*For more than 160 years FM Approvals has partnered with business and industry  
to reduce property losses.*

Richard B. Dunne  
Group Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



Member of the FM Global Group